



Klamath County Fire District No. 1

143 North Broad Street • Klamath Falls, Oregon 97601
Phone: (541) 885-2056 • Fax: (541) 884-6920 • kcf1@kcf1.com

PRESS RELEASE

June 15, 2007
For Immediate Release

Contact: Scott Rice, Deputy Fire Marshal

541-885-2056

Red's B-B-Que

The investigation into the origin and cause of this two alarm structure fire is concluded. The investigation was conducted by Klamath County Fire District No. 1 and the Electrical Inspector from the Klamath County Building Department. The cause of the fire was from arching in one of the two main electrical panels which spread to the attached wall and to the attic. The building has been turned over to the owners.

Based upon initial reports from the business involved, the preliminary damage estimate for this fire is approximately \$100,000. It is possible this amount will increase.

It is estimated that the fire units on scene took one hour to contain the fire. The fire was contained to the room of origin and attic. The building was not occupied at the time of the fire and there were no injuries to firefighters.

If you have questions or desire an interview, please contact Deputy Fire Marshal Scott Rice at 541-885-2056.